



Municipal Corporation of Delhi
Public Health Department : South Zone
Sri Aurobindo Marg, Green Park, New Delhi-110016
dhosouthzone@gmail.com

No: DHO/SZ/2022/ D - 2143

Dated 28/9/2022

1. Name of the School: Balvantray Mehta Vidya Bhawan Anguridevi Shersingh Memorial Academy.
2. School Address: Greater Kailash – II, New Delhi-110048
3. No. of Shift: Morning Timing: 8:00AM to 1:30PM
4. No. of Students: Boys: 1541 Girls: 1066 Total: 2607
5. No. of Staffs: Male: 061 Female: 124 Total: 185

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient: Sufficient
2. The Classrooms are Well Lighted/ ill lighted: Well Lighted
3. The Classrooms are Well Ventilated/ ill ventilated: Well Ventilated
4. The Classrooms are kept / Not kept Neat & Clean: Neat & Clean
5. The Classrooms/Building requires/ do not required Whitewash etc: Not required
6. The Drinking Water is Wholesome/ not wholesome: Wholesome
7. The Latrine arrangement is Sanitary/ insanitary: Sanitary condition from health point of view.

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is sufficient
2. One latrine for 40 male student is required so total is sufficient
3. Separate Toilet arrangement for staff present: Yes/No Yes exist separate for staff
4. The Overall facilities: Good/ Adequate/Inadequate: Adequate from health point of view & valid upto one year from issuance date.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

Deputy Health Officer
South Zone

Dr. Deepak Mittal
Dy. Health Officer/SZ

(Remarks: Certificate is valid for one year)

(VANDANA BABERWAL)
PRINCIPAL

SCHOOL ID-1925273 AFF NO-2730285 EXAM CODE 25220
BALVANTRAY MEHTA VIDYA BHAWAN
ANGURIDEVI SHERSINGH MEMORIAL ACADEMY
G K II NEW DELHI-110048 PH-29221798, 41616607